


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Prof. Dr.rer.nat. Lothar Dunemann

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:
Rotthäuser Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Telefax +49 (0)209 9242-222
Internet www.hyg.de

Our reference: W-326510e-20-AB
Contact person: Dipl.-Ing. (FH) S. Horn

Gelsenkirchen, 25.03.2020

Test - certificate

hygiene-conformity check to the design requirements of
selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthäuser Straße 21
49879 Gelsenkirchen

Test object: Plastic pipe "Fitt Agix"

Manufacturer: FITT S.p.A.
Via Piave, 8
36066 Sandrigo (VI)
Italy

Basis of the examination

- ✓ VDI 6022, sheet 1 (01/2018)
- ✓ SWKI VA104-01 (01/2019)
- ✓ ÖNORM H6021 (08/2016)
- ✓ ÖNORM H6038 (02/2020)

Validity period: 5 years 03/2020 – 03/2025

Test report: W-326510-20-AB



In conclusion it can be stated that the examined Plastic pipe "Fitt Agix", as specified in the test report W-326510e-20-Ho, is in compliance with the above mentioned regulations.

(Dipl.-Ing. (FH) S. Horn)
Section head of Air Conditioning technology
Department of Water Hygiene, Environmental
and Microbiology

(A. Blankenberg)
clerk of Air Conditioning technology
State certified technician
Specialization in heating, air conditioning

issued 25.03.2020, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations were examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.